

EU Declaration of Conformity

issued under the sole responsibility of the manufacturer

Declaration objects: **APC-2000ALW-1** series pressure transmitters.Manufacturer: **APLISENS S.A.,
ul. Morelowa 7, 03-192 Warszawa**

hereby declares under its own responsibility, that the subject of the declaration object complies with the relevant Union harmonization legislation.

The transmitters are comply with the following directives/standards:

- **EMC – 2014/30/EU** dated 26 February 2014

Conformity assessment procedure: module A.

The following standard was applied: EN 12405-1:2021.

- **RoHS – 2011/65/EU** dated 08 June 2011

Conformity assessment procedure: module A.

The following standard was applied: EN IEC 63000:2018.

- **ATEX – 2014/34/EU** dated 26 February 2014

Intrinsically safe (**Exi**) & explosion-proof (**Exd**) versions of the pressure transmitters are accordingly marked:

II 1/2G Ex ia IIC T5/T4 Ga/Gb or

II 1/2G Ex ia/db IIC T6/T5 Ga/Gb

according to the certificate: **KDB 19 ATEX 0011X**

The following standards were applied: EN IEC 60079-0:2018, EN 60079-11:2012, EN 60079-1:2014, EN 60079-26:2015.

Conformity assessment procedure, module B. NB No.1453, Central Mining Institute – National Research Institute, Plac Gwarków 1, 40-166 Katowice. ATEX quality assurance notification, was issued by notified body no. 1453, Central Mining Institute – National Research Institute, Plac Gwarków 1, 40-166 Katowice.

- **EN 12405-1:2021**, Annex B, pressure transmitters, harmonized with the 2014/32/EU Directive, MI-002 (MID)

Part certificate No. **2/26** was issued by the Oil and Gas Institute – National Research Institute, Lubicz Street 25A, 31-503 Kraków. Transmitters are marked with the above-named standard and parts certificate number issued by Oil and Gas Institute – National Research Institute, Lubicz Street 25A, 31-503 Kraków.

Warsaw, 29.01.2026.

Jan Wąsowski
Proxy of the Management Board